


DIMENSION TABLE

PIPE DIA. IN.	TABLE PRESSURE PSI	BEND ANGLE (DEG.)	CONCRETE VOLUME (CY)	CUBE SIZE (FT.)	STIRRUP DIA. (IN.)	STIRRUP EMBEDMENT (IN.)	STIRRUP BAR #
4"	250	11.25	0.21	1.8	5/8	17	5
		22.5	0.43	2.3			
		45	0.77	2.8			
6"	250	11.25	0.48	2.4	5/8	17	5
		22.5	0.95	3.0			
		45	1.79	3.6			
8"	250	11.25	0.86	2.9	5/8	17	5
		22.5	1.65	3.5			
		45	3.22	4.4			
10"	250	11.25	1.39	3.3	5/8	17	5
		22.5	2.62	4.1			
		45	4.97	4.1			
12"	250	11.25	1.94	3.7	5/8	17	5
		22.5	3.91	4.7			
		45	6.89	5.7	7/8	24	7
14"	250	11.25	2.62	4.1	5/8	17	5
		22.5	5.26	5.2	3/4	20	6
		45	9.70	6.4	1	27	8
16"	250	11.25	3.44	4.5	5/8	17	5
		22.5	6.89	5.7	7/8	24	7
		45	12.63	7.0	1 1/8	30	9

APPROVAL	REVISED	<p align="center">TOWN OF EASTON AND EASTON UTILITIES COMMISSION STANDARD DETAILS THRUST BLOCK VERTICLE BEND DIMENSION TABLE</p>
 EU MANAGER OF ENGINEERING DATE		
ISSUED: FEB 15, 2013		STANDARD NO. W-3.01A