


1. Contractor to provide blocking adequate to withstand full test pressure.
2. Pour concrete blocking against undisturbed earth.
3. All concrete shall be commercial grade concrete.
4. Wrap pipe and/or fittings with 2 layers of polyethylene film where in contact with concrete.
5. Keep concrete clear of all joints and accessories.
6. Stirrups shall be stainless steel straps approved by Easton Utilities engineer.

APPROVAL	REVISED	TOWN OF EASTON AND EASTON UTILITIES COMMISSION STANDARD DETAILS  THRUST BLOCK VERTICLE BEND
 EU MANAGER OF ENGINEERING DATE		
ISSUED: FEB 15, 2013		STANDARD NO. W-3.01