



NOTES:

1. ALL PRIMARY AND SECONDARY DUCTS SHALL BE 4" PVC UNLESS SPECIFIED OTHERWISE.
2. INSTALL DUCTS WITH 36" MIN. COVERAGE AND TRENCH MUST BE INSPECTED BY E.U. PRIOR TO BACKFILLING.
3. FULL SIZE TEMPLATE AVAILABLE UPON REQUEST FROM E.U. ELECTRICAL DEPT.
4. 6-4" SECONDARY DUCTS MAXIMUM.

SECTION A-A

€ OF DUCT SLEEVE

APPROVAL

REVISED

Talbot W. Rose *4/25/08*
 EU MANAGER OF ENGINEERING DATE

3 Ø TRANSFORMER PAD
 225-1000 KVA
 (SUPPLIED BY EU)

ISSUED 3/25/11

STANDARD No. E-3.04