



Notes:

1. Tracer Wire Must Be Surfaced Into Valve Box Or Rhino Internal Terminal Style Test Station Every 400' To 500'.
2. Street Openings Shall Be Restored In Accordance With G-4.00.
3. Non-Paved Areas Shall Be Restored To Their Original Condition.
4. Reinforced Coated Tracer Wire As Manufactured By Copperhead Industries, LLC, P.O. Box 1081, Monticello, MN, 55362, Or An Approved Equal.
5. Thoroughly Tape Mechanical Connections With Electrical Tape.

APPROVAL EU MANAGER OF ENGINEERING DATE	REVISED SEP 1, 09	TOWN OF EASTON AND EASTON UTILITIES COMMISSION STANDARD DETAILS NARROW GAS JOINT TRENCH
ISSUED: <u>SEP. 1, 2007</u>	STANDARD NO.	GS-1.03