



Notes:

1. Before Gas Service Is Installed, Service Application Must Be Made At At Easton Utilities Customer Service Center.
2. All Gas Meter Sets Shall Be Installed To NFPA54 ANSI Z 223.1 National Fuel Gas Code And Easton Utilities Gas Department Standard.
3. Gas Service Riser Shall Be Sleeved In PVC Conduit If It Passes Through Concrete, Brick Or Pavement.
4. Easton Utilities Gas Department Shall Be Contacted Regarding Meter Location And Pressure Testing Requirements.
5. Gas Meter Shall Be Located In A Ventilated Space Clear Of Landscaping And Readily Accessible For Examination, Reading, Replacement Or Necessary Maintenance.
6. Gas Meter Shall Be Located At Least 3 Feet From Sources Of Ignition.
7. If Gas Meter Is Equipped With A Regulator, It Shall Be Located At Least 3 Feet From Air Vents And Inlets.

APPROVAL	REVISED	<p style="text-align: center;">TOWN OF EASTON AND EASTON UTILITIES COMMISSION STANDARD DETAILS</p> <p style="text-align: center;">GAS METER INSTALLATION</p>	
<p><i>Talbot W. Bane</i> 4/25/06 EU MANAGER OF ENGINEERING DATE</p>			
ISSUED: MAR 1, 2002			STANDARD NO. GS-2.00