



Notes:

1. Precast Manhole Shall Conform To ASTM C-478(Latest) As Manufactured By: York Concrete Septic Tanks Inc. York Pa. Or An Approved Equal.
2. Mortar Shall Be "Type S".
3. Bench And Channel Shall Be Brick Or Hand Formed Concrete. Min. Thickness Of 4", Bench Shall Slope To Top Of Pipe 1/2" Fall Per Foot.
4. Manhole Steps Required Over Effluent Side As Shown.

APPROVAL	REVISED	TOWN OF EASTON AND EASTON UTILITIES STANDARD DETAILS PRECAST CONCRETE MANHOLE
<i>Talbot W. Bane</i> EU MANAGER OF ENGINEERING	MAY 1, 89	
	AUG 1, 94	
	MAR 9, 95	
	FEB 1, 02	
ISSUED: <u>MAY 1, 1986</u>	DATE	STANDARD NO. SS-1.00