


Notes:

1. Precast Manhole Shall Conform To ASTM C-478-78a As Manufactured By: York Concrete Septic Tanks Inc. York Pa. Or An Approved Equal.
2. Bench & Channel Shall Be Brick Or Handformed Concrete Min. Thickness Of 4", Bench Shall Slope To Top Of Pipe 1/2" Fall Per Foot. Mortar Shall Be "Type S".
3. Manhole Steps, Frame & Cover Shall Be Centered Over Effluent Side Of Manhole.

APPROVAL	REVISED	TOWN OF EASTON AND EASTON UTILITIES STANDARD DETAILS  DROP MANHOLE
 EU MANAGER OF ENGINEERING DATE	MAY 1, 89	
	AUG 1, 94	
	MAR 9, 95	
	MAR 1, 98	
ISSUED: MAY 1, 1986	STANDARD NO.	SS-1.04