



Notes:

1. Service Connection Shall Be Perpendicular To Main.
2. Add Detector Tape To All Pipe.
3. Use Class 50 Ductile Iron For Services With Less Than 3' Of Cover.
4. Reinforced Coated Tracer Wire As Manufactured By Copperhead Industries, LLC, P.O. Box 1081, Monticello, MN, 55362, Or An Approved Equal.
5. Thoroughly Tape Mechanical Connections With Electrical Tape.

APPROVAL

Talbot W. Bane 9/1/09
EU MANAGER OF ENGINEERING DATE

REVISED

- OCT 1, 88
- MAR 1, 94
- AUG 1, 94
- MAR 1, 98
- SEP 1, 09

TOWN OF EASTON
AND
EASTON UTILITIES
STANDARD DETAILS

SEWER HOUSE CONNECTION

ISSUED: MAY 1, 1986

STANDARD NO. SS-8.00