


NOTES:

1. SERVICE CONNECTION SHALL BE PERPENDICULAR TO MAIN.
2. ADD DETECTOR TAPE TO ALL PIPE.
3. USE CLASS 50 DUCTILE IRON FOR SERVICES WITH LESS THAN 3' OF COVER.
4. NO SPLICES ON TRACER WIRE. MECHANICAL CONNECTORS ONLY IN CLEANOUTS.
5. EMBED PIPE IN #57 STONE FROM 6" BELOW INVERT TO 2" ABOVE CROWN.

APPROVAL	REVISED	EASTON UTILITIES STANDARD DETAILS SEWER COLLECTION SYSTEM SEWER HOUSE SERVICE
 EU MANAGER OF ENGINEERING	MAY 1, 89	
	AUG 1, 94	
	MAR 9, 95	
	FEB 1, 02	
	JAN 15, 19	
JAN 15, 2019 DATE		
ISSUED: MAY 1, 1986		STANDARD NO. SS-8.00