

4" Min. Cast Iron Service Weight Or Schedule 40 PVC Pipe

Plan

Ground Surface

Cleanout At Property Line

10 Gauge Reinforced Tracer Wire On All Laterals

5' Min.

Up @ 1.0% Min.

3'

2'-0" Min.
Trench Width
1'-0" Min.

Elevation

Mechanical Connector For All Splices On Wire

See Detail SS-8.00 For Termination From Property Line.

Embed Pipe In Stone

4' x 1/2' Dia. Min. I.R. Or Similar Marker

Wye Branch


Embed Pipe In Stone

Sewer Main

Washed Gravel Bedding

Notes:

1. Add Detector Tape To All Pipe.
2. Use Class 50 Ductile Iron For Services With Less Than 3' Of Cover.
3. Reinforced Coated Tracer Wire As Manufactured By Copperhead Industries, LLC, P.O. Box 1081, Monticello, MN, 55362, Or An Approved Equal.
4. Thoroughly Tape Mechanical Connections With Electrical Tape.

APPROVAL	REVISED	TOWN OF EASTON AND EASTON UTILITIES STANDARD DETAILS DROP SEWER HOUSE CONNECTION
 EU MANAGER OF ENGINEERING DATE	OCT 1, 88	
	MAR 1, 94	
	AUG 1, 94	
	MAR 9, 95	
	SEP 1, 98	
ISSUED: MAY 1, 1986	SEP 1, 09	STANDARD NO. SS-8.01