


Notes:

1. Warning Tape Shall Be Placed 24" Above All Pipe.
2. The Tracing Wire Shall Be A Continuous Conductor Connected To All Fittings And Services.
3. All Fittings Shall Be As Specified In AWWA C110-93, Mechanical Joint, Ductile Iron, Pressure Rated At 350 PSI.
4. All Fittings Shall Be Restrained By Thrust Blocks According To Standard Detail W-3.00.
5. Firm Bearing Shall Be Provided For Full Length Of Pipe.
6. After Pipe Is Installed On Bedding, Place Backfill In Lifts To Springline, Crown And Cover, Tamping After Each Lift. Lifts Not To Exceed 12".
7. Reinforced Coated Tracer Wire As Manufactured By Copperhead Industries, LLC, P.O. Box 1081, Monticello, MN, 55362, Or An Approved Equal.
8. Thoroughly Tape Mechanical Connections With Electrical Tape.

APPROVAL	REVISED	TOWN OF EASTON AND EASTON UTILITIES STANDARD DETAILS PVC FORCE MAIN INSTALLATION
 EU MANAGER OF ENGINEERING DATE	JUN 1, 09	
	SEP 1, 09	
ISSUED: JAN 2, 2001	STANDARD NO.	SS-9.10