



VALVE BOX SECTION

Notes:

1. To Be Plumb And Centered Over Valve.
2. All Sections Shown To Be Gray Iron Castings, Class No. 35 ASTM A-48.
3. Lower Section To Rest On Valve Bonnet.
4. Valve Box To Be Fig. #4905 And As Manufactured By Bingham & Taylor P.O. Box 552 Culpeper, VA. 22701
5. 10 Gauge Coated Solid Copper Tracer Wire Or An Approved Equal.

APPROVAL	REVISED	TOWN OF EASTON AND EASTON UTILITIES STANDARD DETAILS SCREW TYPE VALVE BOX
<i>Talbot W. Bane</i> EU MANAGER OF ENGINEERING	MAR 1, 98	
	SEP 1, 09	
	NOV 1, 10	
ISSUED: AUG 1, 1994		STANDARD NO. W-6.01