



Notes:

1. Stainless Steel Saddle Shall Be Equivalent To Ford FS303 Or PowerSeal 3412AST.
2. Pipe Shall Be Tapped With A Shell Type Cutter (Hole Cutter) That Will Retain The Coupon In Accordance With UNI-BELL Plastic Pipe Association UNI-B-3.
3. Pipe Shall Conform And Be Installed According To AWWA C901 For PE-3408 High Molecular Weight Polyethylene, Equivalent To Orangeburg Poly-XTRA, Class 200 (SDR-9, CTS-OD).
4. The Polyethylene Pipe Shall Be Cut With Approved Cutters Only.
5. Stainless Steel Inserts Shall Be Used At All PE Connections To Fittings.
6. Meter Box (Ford No. PSBHC-488-20-36-18) Or An Approved Equal Furnished And Installed By Contractor. Cover Must Be Polymer Nicor 12.25PWAT1 Type A (Read -Rite) Lid With Water Logo, Worm Gear And Bracket For Itron 60W ERT Under Lid Or Equivalent. No Electronic Meter Reading Lid Hole.
7. Backfill And Tamp With Select Material To Pad Pipe. See Detail W-1.00.
8. 10 Gauge Coated Solid Copper Tracer Wire Or An Approved Equal.
9. Thoroughly Tape Mechanical Connections With Electrical Tape.

APPROVAL	REVISED	TOWN OF EASTON AND EASTON UTILITIES STANDARD DETAILS 1" WATER SERVICE INSTALLATION - PVC WATER MAIN
 EU MANAGER OF ENGINEERING DATE	DEC 12, 94	
	MAR 9, 95	
	MAR 1, 98	
	SEP 1, 09	
	NOV 1, 10	
ISSUED: AUG 1, 1994	JUL 20, 11	STANDARD NO. W-7.02