



Notes:

1. Meter Pit, Frame And Cover, And Customsetter Shall Be Furnished And Installed By The Contractor. Cover Must Be Polymer Nicor 12.25PWATI Type-A (Read-Rite) Lid With Water Logo, Worm Gear And Bracket For Itron 60W ERT Under Lid Or Equivalent. No Electronic Meter Reading Lid Hole.
2. 2" Corporation AWWA Taper Threads Shall Be Installed As Detailed On Standard No. W-7.01.
3. Mueller Part Numbers For 1 1/2" And 2": B-2423--2-01.
4. Reinforced Coated Tracer Wire As Manufactured By Copperhead Industries, LLC, P.O. Box 1081, Monticello, MN, 55362, Or An Approved Equal.
5. Thoroughly Tape Mechanical Connections With Electrical Tape.

APPROVAL	REVISED	TOWN OF EASTON AND EASTON UTILITIES STANDARD DETAILS 1 1/2" AND 2" METER INSTALLATION
<i>Talbot Bane</i> EU MANAGER OF ENGINEERING	MAR 1, 98	
	FEB 1, 06	
	MAR 1, 07	
	SEP 1, 09	
	NOV 1, 10	
ISSUED: MAY 1, 1986	JUL 20, 11	STANDARD NO. W-7.03